



PRECAST CONCRETE UNIT PAVERS:
REFER TO MANUFACTURER'S RECOM-
MENDATIONS FOR INSTALLATION AND
SEALING; REFER TO THE PLANS AND
SPECIFICATIONS FOR PATTERN, PAVER
TYPE, AND COLOUR AND PAVER
DIMENSIONS.

BRUSH POLYMERIC SAND INTO JOINTS
20 MM LEVELLING BED OF COARSE SAND

SOD ON 150 MM TOPSOIL

200X200 MM CONCRETE EDGE RESTRAINT,
30 MPa SAWCUT 3600 MM O.C.

150 MM MINIMUM DEPTH OF 19 MM
CRUSHER RUN COMPACTED TO 98% SPD
SUBGRADE, COMPACTED TO 98% SPD

FIBRE BOARD EXPANSION JOINT
ABUTTING ALL CONCRETE STRUCTURE

152 X 152 X 5 (MW 18.7)
WELDED WIRE MESH. MIN. 50mm COVER

125 MM DEPTH CAST IN PLACE CONCRETE
WITH 6% AIR ENTRAINMENT, 32 MPa

25 MM DIA. DRAINAGE HOLES AT 600 MM
O.C. WITH TERRAFIX 270R FILTER FABRIC
OR APPROVED ALTERNATE OVER TOP

NOTES:

WORKMANSHIP

PAVERS SHALL BE INSTALLED IN STRICT ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS WITH TIGHT BUTT JOINTS OF APPROXIMATELY 3 mm, ON A SAND BASE. SAW CUT PAVERS AS REQUIRED. USE AN APPROVED VIBRATORY COMPACTOR IN A CIRCULAR PATTERN. SPRINKLE SAND OVER AREA TO PREVENT CHIPPING FOR HEAVIER VIBRATORY COMPACTION. ALL DAMAGED OR CHIPPED PAVERS MUST BE REPLACED AT THE CONTRACTOR'S COST. BRUSH SAND INTO JOINTS AND SPRINKLE WITH WATER UNTIL JOINTS ARE FILLED.

EDGE RESTRAINT

REFER TO SPECIFICATIONS. EDGE RESTRAINT MUST BE APPROVED BY LANDSCAPE ARCHITECT PRIOR TO COMMENCING WORK.

PREPARATION

EXCAVATE AND REMOVE ALL TOPSOIL AND UNSTABLE MATERIALS OFF SITE. SUBGRADE TO BE GRADED TO SIMILAR CONTOURS AS FINISH GRADE. COMPACT SUBGRADE TO 98% SPD. PLACE 150 MM LAYER OF 19 mm CRUSHER RUN LIMESTONE, COMPACT TO 98 % SPD.

PLACE MAXIMUM 20 MM UNCOMPACTED SAND FOR LEVELLING COURSE.

ALL MEASUREMENTS ARE IN MILLIMETRES UNLESS STATED OTHERWISE.