



## NOTES:

- 1. GATE FRAMES SHALL BE CONSTRUCTED OF 45 O.D. GALVANIZED STEEL PIPE, SHOP BENT, WELDED, AND GROUND SMOOTH. STRETCHER BARS TO BE 5 x 19 MINIMUM; STRETCHER BAR BANDS 300 O.C., 6 x 19 MINIMUM.
- 2. CHAIN LINK FABRIC TO BE BLACK VINYL COATED 38 WOVEN MESH, 9 GAUGE, SECURED TO STRETCHER BARS AT TOP AND BOTTOM OF GATES WITH 3.5 (9 GAUGE)
- 3. KNUCKLE FASTENERS 254 O.C.
- FINISH TO POSTS, TOP, BOTTOM, MIDDLE RAIL AND FITTINGS TO BE BLACK GLOSS ENAMEL BY POWDER COAT APPLICATION. PRIOR TO POWDER COATING, ALL
- 4. SURFACES TO BE CHEMICALLY CLEANED AND TREATED WITH PARKER BONDERITE AND CHLOROTHENE SOLVENT OR APPROVED EQUAL. POWDER COATING MUST BE A POLYESTER 2000 SERIES APPLIED IN A THICKNESS OF 4-5 MILS BY ELECTROSTATIC COAT AND OVEN CURED TO A SMOOTH AND EVEN SURFACE.
- 5. ALL FENCE POSTS, GATE FRAMES, AND RAILS TO BE GALVANIZED SCHEDULE "40" PIPE.
- 6. PLASTIC COUPLINGS, FITTINGS OR ANY OTHER PLASTIC COMPONENTS WILL NOT BE ACCEPTED.
- 7. WELD ALL JOINTS.
- 8. ALL MEASUREMENTS ARE IN MILLIMETRES UNLESS STATED OTHERWISE.