



NOTES:

1. HYDRO POLES TO BE PLACED 2.0M OFFSET FROM THE PROPERTY LINE INTO THE ROAD ALLOWANCE.
2. MINIMUM 1.0M CLEARANCE FROM TREE CANOPY TO LIVE CONDUCTOR.
3. HYDRO ONE BRAMPTON MAY NOTCH TREE CANOPIES AT 3.0M CLEARANCE TO CONDUCTORS IN SOME CIRCUMSTANCES.
4. TREE SPECIES REFER TO 'ARTERIAL ROAD BUFFER TREES TO PLANT AT HYDRO AERIAL EASEMENTS'.
5. ALL MEASUREMENTS ARE IN MILLIMETERS UNLESS STATED OTHERWISE.