



NOTES:

1. ALL CONCRETE TO BE 30MPa
2. EXPANSION JOINTS OR 0.25 T TO BE PROVIDED EVERY 3m.
3. POST FOOTINGS TO BE SEPARATE FROM WALKWAY
4. 2m PROJECTION AND 1m CURB DEPRESSION MAY VARY WHERE WALKWAY IS ADJACENT TO DRIVEWAY
5. HEIGHT OF FENCE TO BE 1.8m WHEN WALKWAY IS ADJACENT TO A SCHOOL
6. BOTTOM RAIL TO BE INSTALLED AS PER PDD 830

DIMENSIONS IN mm UNLESS OTHERWISE NOTED



APPROVED:
2010/12/01

STANDARD
CONCRETE WALKWAY

ORIGINAL:
1993/11/10

REV. 3

227

N.T.S