



BRAMPTON
Flower City

brampton.ca

BEDDING STONE
& SAND COVER

GRAIN SIZE DISTRIBUTION


APPROVED:
1997/04/02

ORIGINAL:
1993/11/01

REV. 1

348

N.T.S



M.I.T. SYSTEM	COBBLE SIZE		GRAVEL SIZE		SAND SIZE			FINES
	COARSE	FINE	COARSE	FINE	COARSE	MEDIUM	FINE	
UNIFIED SYSTEM	COBBLE SIZE		GRAVEL SIZE		SAND SIZE			FINES
	COARSE	FINE	COARSE	FINE	COARSE	MEDIUM	FINE	

SAND COVER	
SIEVE SIZE / OPENINGS	% PASSING BY WT. SPECIFIED
9.50mm	100
6.70mm	77-100
4.75mm	55-100
2.36mm	35-100
1.18mm	20-100
600um	15-82
300um	10-50
150um	4-20

BEDDING STONE	
SIEVE SIZE / OPENINGS	% PASSING BY WT. SPECIFIED
26.50mm	100
19.00mm	85-100
16.00mm	50-90
13.20mm	45-80
9.50mm	35-65
4.75mm	12-30
2.36mm	7-23
1.18mm	4-20
150um	0-10

"CHIP STONE" BEDDING	
SIEVE SIZE / OPENINGS	% PASSING BY WT. SPECIFIED
13.2mm	100
9.5mm	95-100
4.75mm	60-85
2.36mm	15-30
1.18mm	0-10
600um	0-7
150um	0-4
75um	0-3