



SINGLE CONNECTIONS TO ACCOMMODATE HYDRANT ON LOT LINE LOCATION

LEGEND:

- T.F. TEST FITTING
- V. VALVE

NOTES:

1. WHERE DRIVEWAYS ARE CONSTRUCTED OVER CONNECTION CORRIDOR THE WATER VALVES MUST BE LOCATED IN CENTRE OF UNIT BEING SERVICED.
2. SHALLOW AND DEEP CORRIDORS ON ALTERNATING LOT LINES.
3. ON TOWNHOUSE SITES AND LOTS 11m OR LESS DEEP SERVICES MUST BE LOCATED UNDER DRIVEWAYS.
4. SINGLE FAMILY, SEMI-DETACHED & STREET TOWNHOUSES USE 150mm CONC OR 125mm PVC PIPE FOR SINGLE OR DOUBLE CONNECTIONS. TEST 'T' SHALL HAVE THE WORD 'STORM' STAMPED INTO THEIR TOP SIDE FOR IDENTIFICATION. PVC PIPE SHALL BE COLOUR CODED WHITE. 'BOOTJACK' TO BE 125x125.
5. MULTIPLE FAMILY, COMMERCIAL OR INDUSTRIAL PIPE SIZE TO BE DETERMINED USING RATIONAL FORMULA & APPROPRIATE RUN-OFF COEFFICIENTS MIN. 150mm.

ALL DIMENSIONS IN mm UNLESS OTHERWISE NOTED



APPROVED:
1996/02/07
**STANDARD CONNECTION
LOCATIONS FOR SINGLE LOTS,
SEMI LOTS AND
STREET TOWNHOUSES**
ORIGINAL:
1990/11/01

REV. 5

356

N.T.S