



NOTES:

1. TRANSFORMER SUPPLY PEDESTAL. FEED CABLE TO BE 3 #2 COPPER (RED, BLACK & WHITE MINIMUM SIZE)
2. STATION SHELTER. FEED CABLE TO BE 3 #6 COPPER (RED, BLACK & WHITE MINIMUM SIZE) & #6 AWG GROUND
3. GROUND WIRE TO BE #6 AWG COPPER
4. NEUTRAL GROUND BONDING LOCATION

ALL DIMENSIONS ARE IN MILLIMETERS
UNLESS OTHERWISE NOTED.



BRAMPTON
Flower City

POWER SUPPLY
ARRANGEMENTS
(SINGLE PHASE)
GENERAL - SERIES 400

APPROVED:
DEC 2015

ORIGINAL:
AUG 2015

REV. 1

492

N.T.S