



NOTE:

1. CU CONDUCTOR MUST ALWAYS BE POSITIONED BELOW OR UNDERNEATH AL CONDUCTOR AT POINT OF CONNECTION
2. NO BOLT HOLES ON HOB POLES TO BE COVERED BY ADDED HARDWARE
3. GUARD TO BE MINIMUM 2400MM FROM FINAL GRADE WHERE NO SERVICE DISCONNECT PANEL AVAILABLE
4. DETAIL 'A' AND DETAIL 'B' CAN BE COMBINED FOR OVERHEAD TO OVERHEAD/UNDERGROUND SERVICE
5. STREET LIGHT SERVICE ENTRANCE NOT TO BE INSTALLED ON POLES ADJACENT TO ROAD CROSSINGS AND DRIVEWAY

ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE NOTED



BRAMPTON
Flower City

**STREET LIGHTING
SERVICE ENTRANCE**

OVERHEAD TO OVERHEAD AND
OVERHEAD TO UNDERGROUND

STREET LIGHT DETAILS - 500

APPROVED:
MARCH
2017

ORIGINAL:
JUNE 2006

REV. 4

501

N.T.S