



NOTE:

1. PROVIDE MINIMUM 10 FEET OF 4-#12 (BLACK, RED, WHITE, GREEN) WIRE FROM PHOTO CONTROL TO SPLIT DUPLEX RECEPTACLE AND 3x20 FT. #12 AWG COPPER STRANDED LEADS (BWG) 600V RW90.
 2. LEVITON T7599 GFCI TO BE USED
 3. REFER TO STD. 525 FOR POLE ANCHOR INSTALLATION DETAILS.
- ALL DIMENSIONS IN mm UNLESS OTHERWISE NOTED



BRAMPTON
Flower City

4.3m DOWNTOWN
STREET LIGHT

STREET LIGHT DETAILS - 500

APPROVED:
MARCH
2017

ORIGINAL:
JUNE 2006

REV. 2

523

N.T.S