



NOTE:

1. LEAVE COILS FOR FINAL CONNECTION BY HYDRO ONE BRAMPTON.
2. #6 CU. BARE GRD. WIRE REQUIRED FOR #2 AL DUPLEX AND 3/0 AL TRIPLEX.

FOR MAINTENANCE ONLY



BRAMPTON
Flower City

STREET LIGHT
SUPPLY

OVERHEAD TO UNDERGROUND
STREET LIGHT DETAILS - 500

APPROVED:
APRIL 2014

ORIGINAL:
JUNE 2006

REV. 0

540

N.T.S