



MATERIAL

- a. 1/4"-20x3/4" THREADED CORE.
- b. 1/4"-20x3/4" ALLEN KEY BUTTON PAN HEAD STAINLESS STEEL BOLT C/W ANTI-SEIZE COMPOUND
- c. GROUNDING LEAD - USE NO. 6 AWG MIN. STRANDED CU. WIRE, THREE TURNS, CRIMPED TO STEEL ROD. LEAD TO EXTEND 305mm OUTSIDE THE HANDHOLE.
- d. CAST METALLIC HANDHOLE FRAME AND COVER.

NOTE

1. DIMENSIONS SHOWN ARE IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.
2. POLE TO BE CONSTRUCTED AS PER CSA A14-M (LATEST REVISION)
3. METALLIC HANDHOLE FRAME MUST BE ELECTRICALLY BONDED TO THE NO. 6 GROUND WIRE.

FOR MAINTENANCE ONLY



TENON POST TOP ROUND
 C.S.A. CLASS 'A' 7.6m (25FT) PRE-STRESS CONCRETE POLE
 STREET LIGHT DETAILS - 500

APPROVED:
 MARCH 2017
 ORIGINAL:
 JUNE 2006

REV. 1
543
 N.T.S